LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 1330e-(cl-6)

lssue: 01

Lichfield Fire & Safety Equipment Co. Ltd

Unit 8, Calibre Industrial Park, Laches Close, Four Ashes, Wolverhampton, WV10 7DZ, United Kingdom



PКЕ

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Line Units LF-X5210 (Refer to Appendix for details)

Standards

EN 54-18:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Walligar.	P Halligan	13 October 2023	13 October 2023	
Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue	



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit <u>www.redbooklive.com/terms</u>). To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/check</u>, scan the QR tag or contact us. BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

LPCB®

Appendix to Certificate No: 1330e-(cl-6)

Issue: 01

Lichfield Fire & Safety Equipment Co. Ltd

Certified Product	Description	
LF-X5210	Addressable Single Input/Output Module	1330e/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Walligar.	P Halligan	13 October 2023	13 October 2023
Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue
Subject to terms and condit To check the validity of this www.redbooklive.com/chec BRE Global Ltd, Watford, W T: +44 (0)333 321 8811 E: 6			

80018