

## Certificate of Product Approval

Certificate Number: 1330d-(cl-6)

Issue: 01

### Lichfield Fire & Safety Equipment Co. Ltd

Unit 8, Calibre Industrial Park  
Laches Close  
Four Ashes  
Wolverhampton  
WV10 7DZ  
United Kingdom

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Alarm Warning Devices

LF-X5300

LF-X5302

(refer to Appendix for details)

#### Standards

EN 54-3:2014 + A1:2019

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan

13 October 2023

13 October 2023

Signed for BRE Global Ltd

Verifier

Date of Issue

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1330d-(cl-6)

Issue: 01

### Lichfield Fire & Safety Equipment Co. Ltd

Certified Product	Description	LPCB Ref.No.
LF-X5300	<p>Addressable Sounder Strobe (LF-X5300 Sounder Base)</p> <p>Notes:</p> <ol style="list-style-type: none"> <li>Approved to Type A Indoor use only.</li> <li>Meets the requirements of EN 54-3 at the following tones:                             <ul style="list-style-type: none"> <li>Tone 14, 2400 Hz – 2900 Hz @ 3Hz</li> <li>Tone 16, 500Hz – 1200Hz, 3.75s on/0.25s off</li> <li>Tone 17, 800Hz, 1s off/1s on</li> </ul> </li> </ol> <p>The strobe function is not approved to EN 54-23</p>	1330d/01
LF-X5302	<p>Addressable Sounder Base</p> <p>Notes:</p> <ol style="list-style-type: none"> <li>Approved to Type A Indoor use only.</li> <li>Meets the requirements of EN 54-3 at the following tones:                             <ul style="list-style-type: none"> <li>Tone 14, 2400 Hz – 2900 Hz @ 3Hz</li> <li>Tone 16, 500Hz – 1200Hz, 3.75s on/0.25s off</li> <li>Tone 17, 800Hz, 1s off/1s on</li> </ul> </li> </ol> <p>The strobe function is not approved to EN 54-23</p>	1330d/02

### Bases

LF-X5300 Sounder Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

13 October 2023

Date of Issue

13 October 2023

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


